



Addendum No. 1

US1 Undergrounding – Electrical

Project Name: Service Conversions

Client: City of South Daytona

Project Location: South Daytona, Florida

Client Representative: Josh McEnany

Project Number: Bid No. 25-ITB-009

Mead & Hunt, Inc. Manager: David King, PE

Date: March 26, 2025

Mead & Hunt Inc. Phone: (386) 761-6810

TO ALL BIDDERS: You are requested to make all changes and/or additions contained in this Addendum to the Bidding Documents. Failure to acknowledge this Addendum in Proposal shall result in rejection of bid.

BID DATE AND TIME SHOULD CORRESPOND TO DATE AND TIME INDICATED IN ADVERTISEMENT FOR BIDS, UNLESS DATE AND TIME HAS BEEN CHANGED IN THIS OR PREVIOUS ADDENDUMS.

CLARIFICATIONS

1. Service wire is to be copper versus aluminum as shown on plans. The revised wire and conduit for each service is as follows:
 - a. 2270 Dairy Queen: 400A, 3" 3-500CU
 - b. 2323 Exxon: 600A, 2X 3" 4-350CU
 - c. 2309 Thao Cuisine: 200A, 2" 3-3/0CU
 - d. 2200 Honest auto Care: 400A, 3" 3-500CU
 - e. 2227 Hometown Auto: 200A, 2" 4-3/0CU
 - f. 2225 Korean Garden: 400A, 4"4-500CU
 - g. 2156 Long John Silvers: 400A, 4" 4-500CU; 200A, 2" 4-3/0CU; 200A, 2" 4-3/0CU
 - h. 2164 Reliable Auto: 200A, 2" 3-3/0CU
 - i. 2174 Herb Realty/Image Salon: 400A, 3" 3-500CU
2. For most cases, the proposed FPL service location/handhole is to be at the existing overhead service pole. In some cases, the future FPL service location/handhole after the primary undergrounding is different than existing overhead service pole. The electrical service conversion plans show these future locations/handholes and conduit and wire to such, if applicable. The contractor shall provide additional coordination with FPL as needed for the varying service locations. This may include postponing the electrical service conversion until FPL is able to serve from the alternate location.

END OF ADDENDUM

Disclaimer: This addendum was posted on the City website, www.southdaytona.org. It is the sole responsibility of bidder to confirm that all addenda have been received prior to submitting bid and acknowledge such in the bid documents.