



City of South Daytona Bid Addendum

RFP Title:	2025-ITB- 017 US 1 Streetlights
Bid Addendum Number:	2
Bid Addendum Date:	July 17, 2025

June 20, 2025	Distribute RFP Document
July 1, 2025 July 10, 2025 at 2:00 PM	Pre-Bid Conference at City Hall, 1672 S. Ridgewood Avenue, South Daytona
July 18, 2025 July 25, 2025 by 5:00 PM	Written Questions Due Questions regarding responses to this bid must be in writing through e-mail to Becky Witte, Deputy City Clerk at bwitte@southdaytona.org .
July 22, 2025 July 29, 2025 by 5:00 PM	City to respond to Questions
July 31, 2025 August 7, 2025 at 2:00 PM	Proposals Due to the City
TBD	Selection Committee Meeting (<i>tentative date</i>)
August 12, 2025	Staff Recommendation to the City Council

SCOPE OF WORK:

FPL no longer allows unmetered services for City-owned streetlights. Therefore, FPL meters and City-owned distribution (conduit/wire) will be required. The construction plans are being revised accordingly to include the conduit/wire, meters and related work and will be provided via Addendum #3.

Streetlight fixtures are to be Acuity/Halophane Esplanade Tear Drop Large Roadway Pendants, Standard Housing, 247W, 3000 Series CCT, Teardrop Glass & Door, Type 3 Application, Shallow Skirt, 30" Diameter, Black, Model ESL3 P65S 30K MVOLT TG3 BK SS.

Streetlight arms are to be Acuity/Halophane WLC Series West Liberty Aluminum Roadway Arm, Black, Model WLC 72IN 1A TN BK.

Streetlight poles are to be Ameron Centrecon M-Series Round Pole, Embedded, Model MERX13, color to match existing poles.