



**City of South Daytona**  
**Sewer Rehabilitation Services**  
**BID NO. 23-B-005**  
**Addendum #1**

**Monday, March 20, 2023**

***Questions Received. Answered from the City of South Daytona are in RED.***

Can TDS sheets be submitted in an effort to get our supplier MTC polyester resin lining system approved as a product on this bid.

Per Part – 2 Products, C. (Resin) 3) of the technical spec: If they wish to offer an alternative, the following shall be provided:

“Therefore, the basis of design shall be 100% epoxy resin, or approved equal. Requests for consideration of equivalent resins other than 100% epoxy shall include a detailed comparison of the benefits & disadvantages (i.e. pros and cons) of the alternate resin system versus the basis of design 100% epoxy resin over the lifecycle of the product.”

Please include the comparison information required in the bid when submitting. The Selection Committee will review the submittal.